



MODEL	A			VOLUME			DOME VOLUME			WEIGHT	
	mm	inch	+/-	liters	U.S. gal	cubic FT	liters	U.S. gal	cubic FT	Kg	LBS
8x44	1132	44.57	5 .20	32.1	8.48	1.13	0.88	0.23	0.03	5.50	12.1

- NOTES:
- TANK MUST MEET ALL APPLICABLE SPECIFICATIONS OF NSF/ANSI 044 STANDARD, LATEST REVISION.
 - OPERATING SPECIFICATIONS:
 - A. MAXIMUM WORKING PRESSURE - 150 PSI (10.5BAR)
 - B. TEMPERATURE RANGE - 34-120° F(1-49°C)
 - C. MAXIMUM VACUUM - 5"Hg (127mm Hg)
 - VISUAL LINER INSPECTION
 - A. NO MORE THAN 10 INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS.
 - B. NO INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS LARGER THAN 3×3mm.
 - C. NO INTERNAL BLEMISHES OR BURNT DEBRIS ALLOWED.
 - ALL GLASS STRANDS FROM FIBERGLASS LINER TO BE BONDED AND COVERED.
 - SURFACE TO BE FREE OF NICKS, SCRATCHES, RESIN AND GLASS.
 - SURFACE FINISH.
 - DIMENSIONS IN PARENTHESIS ARE REFERENCE ONLY.
 - DIMENSIONS IN SQUARE PARENTHESIS ARE INCH UNIT.

1		THIS DRAWING IS TREATED CORRECTING WITH THE CHANGE VERSION		DESCRIPTION OF CHANGES:		SIGNATURE:	2008/07/21
VERSION NO.		REPERENTIAL PLASTIC SHRINKAGE (IF NECESSARY):				SIGNATURE:	DATE
SIGNATURE		NAME		DATE		WAVE CYBER (SHANGHAI) CO., LTD.	
DESIGN	SCALE	MATERIAL	MODEL	DESCRIPTION			
INSPECTION	1 : 4	SMOOTHNESS	8" TANK (SIDE HOLE)				
APPROVAL	QUANTITY	PROJECTION	COMPUTER CODE	DRAWING NO.	VERSION NO.		
		DO NOT MEASURE THE DIMENSIONS.		UNIT: MM	TOTAL PAGE: 1		